

From: [Aram Varjabedian](#)
To: tberardinelli@town.hull.ma.us; [Bill Boornazian](#); [david.burns \(david.burns@state.ma.us\)](mailto:david.burns@state.ma.us); [Jim Dow](#); [Frank Cavaleri](#); [Joyce, Ryan \(FWE\)](#); [John Struzziery](#); [jsullivan \(jsullivan@town.hull.ma.us\)](mailto:jsullivan@town.hull.ma.us); [kbornheim \(kbornheim@town.hull.ma.us\)](mailto:kbornheim@town.hull.ma.us); [Krahforst, Chris \(ckrahforst@town.hull.ma.us\)](mailto:ckrahforst@town.hull.ma.us); [Lemnios, Philip \(plemnios@town.hull.ma.us\)](mailto:plemnios@town.hull.ma.us); [Carol O'Connor](#); [Robert Scott](#); [Turin, David](#); [bkiely](#)
Cc: [Peter Lyons](#)
Subject: RE: SSO Notification - Hull, MA - MA0101231 - Sewer Interceptor F Street/Nantasket Ave.
Date: Tuesday, December 10, 2019 3:17:31 PM
Attachments: [image002.png](#)

Good afternoon. I am forwarding to you information received from Peter Lyons, Project Engineer. On behalf of the Town of Hull, Woodard & Curran is hereby notifying MassDEP Southeast Region and EPA Region 1 of a Sanitary Sewer Overflow [SSO] which occurred on 12/9/2019 at the intersection of Nantasket Avenue and F Street at approximately 4:45PM. The cause of the SSO was due to construction activities as the Town is currently lining it's 36-inch Interceptor. Specifically, the temporary wastewater bypass piping was struck at the discharge location by a tractor trailer truck. The current estimate for the SSO is between 5,000-10,000 gallons. The spillage did not make it's way to the receiving waters, as the catch basin in the area appeared to be leaching basin. Sandbags were in place within 10-minutes after the spill directing the wastewater to the sewer manhole. The Contractor vactored the affected catch basin and the affected street area was washed down and vactored up as well.

The Contractor and Town has responded to this event and a formal report will be submitted within 5 days of the occurrence.

In the meantime, should you have any questions please do not hesitate to contact me.

Peter Lyons, P.E.

Project Engineer

Woodard & Curran

980 Washington Street, Suite 325

Dedham, MA 02026

Ph. 978-482-7901

[Aram Varjabedian - Plant Manager](#)

Hull Wastewater Treatment Facility

1111 Nantasket Avenue

Hull, MA 02045

Phone 781.925.0906, Fax 781.925.3056, Cell 339.214.8334

www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS